

# Annexure C

## PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 01

Dated: 29.07.25

It is certified that an inspection team headed by SYED EBADULLAH

(Name of Officers with designation) from PSO, PSM, G. B. Nagar PHED

inspected the Allahabad Public School, Baidpura, Gautam Buddha Nagar

(Name & Address of the school) on 21-07-2025 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. SITL 252600007026 dated 21-07-2025

of Shanti Industrial Testing Lab (PHED Lab) certified that


the ALLAHABAD PUBLIC SCHOOL (Name of school) has safe drinking water

facilities for the students and members of staff of the institution School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 30.01.26

Signature with Seal: 

Name SYED EBADULLAH

Designation Food Safety Officer

Name & Address of the Office / Department :

**SYED EBADULLAH**  
**FOOD SAFETY OFFICER**  
**GAUTAM BUDH NAGAR (U.P)**

To Allahabad Public School  
Baidpura, Greater Noida, G.B. Nagar  
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

Nirmal Sharma  
**Principal**  
**Allahabad Public School**  
**Baidpura, Greater Noida**

Vikas Pandey  
**Manager**  
**Allahabad Public School**  
**Baidpura, Greater Noida**

8279630983  
9027828333

sitr.llp@gmail.com

LLP Identification No. ACL-9789

# SHANTI INDUSTRIAL TESTING LABORATORY LLP

( An ISO 9001:2015, ISO 14001:2015, ISO 45001:2018)



## TEST REPORT

REPORT NO.	SITL252600007026	PAGE	1 of 1
ULR NO	TC16117250000080F	Format NO	F-31, Clause-7.8
SERVICE REQUEST NO.	25260000780	SERVICE REQUEST DATE	21.07.2025
REPORT ISSUE DATE	23.07.2025	SAMPLE RECD. ON	21.07.2025
NAME & ADDRESS OF CUSTOMER		SAMPLE DETAILS	
M/s. Allahabad Public School, Baidpura Bisrakh Block , Gautam Buddh Nagar , Noida,U.P		Description: Drinking water sample Sample Marking : RO Water Submitted by/ Condition of sample By Customer/Unsealed Sample Quantity & Packing : 2.0 Ltr.& Plastic Bottle Analysis Done on : 21.07.2025 to 23.07.2025	

## TEST RESULTS

S.NO.	TEST PARAMETER	TEST METHOD	RESULTS	UNIT	LIMITS AS PER IS-10500-2012	
					DESIRABLE LIMIT	PERMISSIBLE LIMIT
<b>A. CHEMICAL TEST PARAMETERS</b>						
10.	Fluorides (as F)	IS:3025 (Pt-60)Sec-1,2023	0.18	mg/l	1.0 (Max.)	1.5
11.	Nitrate (as NO <sub>3</sub> )	IS:3025 (Pt-34)Sec-1,2023	1.41	mg/l	45	No relaxation
12.	Iron (as Fe)	IS:3025 (Pt-53)2024	<0.01	mg/l	0.3 (Max.)	No relaxation
<b>B. BACTERIOLOGICAL TEST PARAMETERS</b>						
1.	Total coliform	IS:15185-2016	Absent	Per 100ml	Absent/100ml	
2.	E.coli	IS:15185-2016	Absent	Per 100ml	Absent/100ml	

*Aizmal Sharma*  
Principal  
Allahabad Public School  
Baidpura, Greater Noida

*Vikas Pandey*  
Manager  
Allahabad Public School  
Baidpura, Greater Noida



Sudesh Kumar  
Authorised Signatory

Checked by *Akash*

### Note :

1. Test results listed refer only to the sample and applicable parameters, Endorsement of products is neither inferred nor implied.
2. The sample will be stored up to one month (in case of non perishable items only) from the date of issue of test report.
3. This is not to be reproduced wholly or in part and cannot be used as an evidence in the court of law.
4. Total liability of the laboratory is limited to the invoiced amount

KH No-1936, Nagla Rambal Mauza Naraich, Bamrauli Katara (100 Fit Road Opp. RB Degree College, Kalindi Vihar Agra-282006



**TEST REPORT**

REPORT NO.	SITL252600007026	PAGE	1 of 1
ULR NO	TC161172500000080F	Format NO	F-31, Clause-7.8
SERVICE REQUEST NO.	25260000780	SERVICE REQUEST DATE	21.07.2025
REPORT ISSUE DATE	23.07.2025	SAMPLE RECD. ON	21.07.2025
<b>NAME &amp; ADDRESS OF CUSTOMER</b>		<b>SAMPLE DETAILS</b>	
M/s. Allahabad Public School, Baidpura Bsrakh Block , Gautam Buddh Nagar , Noida,U.P		Description: Drinking water sample Sample Marking : RO Water Submitted by/ Condition of sample By Customer/Unsealed Sample Quantity & Packing : 2.0 Ltr.& Plastic Bottle Analysis Done on : 21.07.2025 to 23.07.2025	

**TEST RESULTS**

S.NO.	TEST PARAMETER	TEST METHOD	RESULTS	UNIT	LIMITS AS PER IS-10500-2012	
					DESIRABLE LIMIT	PERMISSIBLE LIMIT
<b>A. CHEMICAL TEST PARAMETERS</b>						
1.	pH Value	IS:3025 (Pt-11)2022	7.44	-	6.5 – 8.5	-
2.	Odour	IS:3025 (Pt-5)2018	Agreeable	-	Agreeable	
3.	Turbidity	IS:3025 (Pt-10)2023	<1	NTU	1 (Max.)	5
4.	Total Dissolved Solids(TDS)	IS:3025 (Pt-16)2023	130	mg/l	500 (Max.)	2000
5.	Total Hardness (as CaCO <sub>3</sub> )	IS:3025 (Pt-21)2009	37.41	mg/l	200 (Max.)	600
6.	Calcium (as Ca)	IS:3025 (Pt-40)2024	11.4	mg/l	75 (Max.)	200
7.	Magnesium (as Mg)	IS:3025 (Pt-46)2023	2.14	mg/l	30 (Max.)	100
8.	Total Alkalinity (CaCO <sub>3</sub> )	IS:3025 (Pt-24)2024	52.0	mg/l	200 (Max.)	600
9.	Chlorides (as Cl)	IS:3025 (Pt-32)1988	13.2	mg/l	250 (Max.)	1000

*Nishant Sharma*  
Principal

Allahabad Public School  
Baidpura, Greater Noida

*Vikas Pandey*  
Manager

Allahabad Public School  
Baidpura, Greater Noida



Sudesh Kumar  
Authorised Signatory

Checked by

ote :

1. Test results listed refer only to the sample and applicable parameters, Endorsement of products is neither inferred nor implied.
2. The sample will be stored up to one month (in case of non perishable items only) from the date of issue of test report.
3. This is not to be reproduced wholly or in part and cannot be used as an evidence in the court of law.
4. Total liability of the laboratory is limited to the invoiced amount



KH No-1936, Nagla Rambal Mauza Naraich, Bamrauli Katara (100 Fit Road Opp. RB Degree College, Kalindi Vihar Agra-282006

